## MGS2500B ST2



Mitsubishi Jeneratör Setleri



### **Prime Power**

Refers to the main power supply, working under 70% average load for unlimited time. 10% overloading is allowed.

**Stand-by Power**Refers to the back up power supplied to the varying load for a limited time. Overloading is not allowed.

### Generator

			Prime		Stand-by
Power (kVA)	kVA		1800		2000
Power kW	kW		1440		1600
Generator Model:				MGS2500B ST	2
Engine Manufacturer Model:				Mitsubishi / S1	.6R-PTA-S
Fuel Type:				Diesel	
Frequency:				50 Hz	
Power Factor:				$Cos \Phi = 0.8$	
Voltage:				400/231 V	
Dimensions			With Ca	nopy	Open Skid
Length		mm	TBA		5385
Height		mm	TBA		2935
Width		mm	TBA		2490
Weight		kg	TBA		12200
Fuel Tank Capacity		lt	TBA		TBA

H: External K: Container TBA: To be added



# **Your Solution Partner in Energy**

## MGS2500B ST2



# litsubishi Jeneratör Setleri

## Engine

Engine Manufacturer:		MITSUBISHI
Engine Model:		S16R-PTA-S
Engine Type:		4 Stroke Diesel Engine
Engine Stand-by Power:	kWm	2000
Engine Prime Power:	kWm	1523
Cylinder Arrangement:		V16
Displacement:	lt	65.4
Cooling System:		Water Cooling
Bore x Stroke:	mm	170 x 180
Compression Ratio:		14:1
Aspiration:		Turbocharged, Aftercooler
Governor Type:		Elektronic
Electrical System:	VDC	24
Lubricant Oil Capacity:	lt	230
Coolant Capacity:	Lt	
Frequency Lt:	Hz - rpm	50 - 1500
Jacket Water Heater:	Piece x W	
Battery:	Piece x AH	
Charge Alternator Current:	Α	
Injection System:		Direct
Cooling Air Flow:	m³/min	2040
Combustion Air Flow:	m³/min	143
Exhaust Gas Flow:	m³/min	378
Exhaust Gas Temperature:	°C	530
Fuel Consumption Under 100% Load:	lt/h	369
Fuel Consumption Under 75% Load:	lt/h	275
Fuel Consumption Under 50% Load:	lt/h	184,5

## Alternator

Phase / Pole Number:		3/4+
Excitation System:		Self Excited, Brushless
Voltage Regulator:		A.V.R. (Automatic)
Voltage Regulation:		± 0,5 %
Insulation Class:		Н
Protection Class:		IP23
Connection Type:		Star
Frequency:	Hz	50
Power Factor:		0.8
Total Harmonic Distortion (No Load):		< % 3.5
Output Voltage:	VAC	231 / 400

TBA: To be added

